



State of Utah

JON M. HUNTSMAN, JR.  
Governor

GARY R. HERBERT  
Lieutenant Governor

Department of Administrative Services

D'ARCY DIXON PIGNANELLI  
Executive Director

Division of Facilities Construction and Management

F. KEITH STEPAN  
Director

## ADDENDUM #3

Date: 29 September 2005

To: Contractors

From: Bob Anderson, Project Manager

Reference: State Office Building  
Elevator Upgrades  
DFCM Project No. 05121050

Subject: **Addendum No. 3**

Pages Addendum 1 Page

---

**Note: This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.**

### 1.1 DIVISION ONE

- 1.1.1 Section 01900, Page 1, Item 1.01.C.2. Add the following,  
“Elevator Contractor is responsible for modification or replacement of machine room, main line power disconnect switches, if required to suit new hoist machines and associated components.”
- 1.1.2 Section 01900, Page 1, Item 1.01.D.1, 2, 3, 4, 5, 6. Omit requirements.  
(Requirements for standby power will be handles directly by Owner. Elevator Contractor provide system within control to allow successive operation of elevators, one car at a time, on standby power when provided appropriate signal.)

### 1.2 SECTION 14220

- 1.2.1 Page 9, Item I. Modify to read, “at a future time, upon loss of normal...”

*End of Addendum*